

Preliminary Assessment Report

Project 3022961, 8532 MIDVALE AVE N

Assessment Completed: 12/8/2015

Project Description: SDR - Construct 5,512 sq ft, residential building (townhomes) with 3 units and 4 parking spaces.

Primary Applicant: [Dennis Christianson](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with DPD. **Please bring a copy of this report to your intake appointment.**

Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

DPD Drainage Requirements

Valerie Monsey, (206) 684-8613, valerie.monsey@seattle.gov

DPD Land Use Requirements

Lori L Swallow, (206) 684-5627, Lori.Swallow@Seattle.Gov

DPD Preapplication Site Visit Requirements

Kathleen H Wilson, (206) 233-7932, Kathleen.Wilson@seattle.gov

Seattle City Light Requirements

Ray Ramos, (206) 615-1193, ray.ramos@seattle.gov

Seattle Department of Transportation Requirements

Leo Kaarrekoski, leo.kaarrekoski@seattle.gov

Seattle Public Utilities Requirements

Jim Mahady, (206) 684-5950, Jim.Mahady@seattle.gov

Water Availability

SPU Staff, (206) 684-3333, SPUWaterAvailability@Seattle.Gov

Other Resources

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [DPD](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

Requirements

DPD Drainage Requirements

The following requirements are based on the current stormwater and side sewer codes.

****The new 2016 Stormwater Code becomes effective on January 1, 2016. Projects with an accepted application (successful DPD permit intake) date after December 31, 2015 will be reviewed under the new code. The drainage requirements indicated below are based on the 2016 Stormwater Code. If your project will be submitted prior to January 1, 2016, please contact the DPD Drainage Reviewer to determine drainage requirements.****

Existing Public Drainage Infrastructure

Sanitary sewer main location: **Midvale Ave N**

Sanitary sewer main size: **8 inch diameter concrete**

Storm drainage main location: **N 85th St**

Storm drainage main size: **30 inch reinforced concrete**

Other location: **Midvale Ave N**

Other size: **Unknown 12 inch diameter drainage pipe starts approx. 70 feet to south of lot**

Project Type and Drainage Basin

The drainage point of discharge (SMC 22.805.020) is located at: **Weep hole**

Project Type: **Parcel-based**

Drainage Basin: **Small lakes**

Drainage Control Compliance

Drainage Review Required: **Yes**

Drainage Control Review is required for this project per SMC 22.807.020. Submit a completed **Standard Construction Stormwater Control and Post Construction Soil Management (CSC/SOIL) Plan** and a completed **Standard Drainage and Wastewater Control (DWC) Plan** including the **Site and Drainage Control Summary** from [On-site Stormwater Management Calculator](#).

Note: For projects with 5,000 square feet or more of new plus replaced hard surface, a comprehensive drainage control plan, construction stormwater control plan, soil amendment plan, and drainage report shall be prepared by a licensed engineer.

Soil Amendment Required: **Yes**

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.030.A, 22.805.040.A, or 22.805.050.A. Complete the **Post Construction Soil Management Plan** on the [Standard CSC/SOIL Plan](#).

On-site Stormwater Management Required: **Yes**

Parcel-based projects with 7,000 square feet or more of land disturbing activity, 1,500 square feet or more of new plus replaced hard surface or, if on a lot or parcel created or reduced in size on or after January 1, 2016, 750 square feet or more of new plus replaced hard surface, must implement **On-site Stormwater**

Management (infiltration, dispersion, bioretention, green roofs, permeable pavement, rainwater harvesting, etc.) to manage runoff from all hard surfaces on-site per SMC 22.805.050.B. and Director's Rule 21-2015.

Flow control standards must be first met by utilizing **On-site Stormwater Management** to the maximum extent feasible. Additional flow control measures shall be installed if the flow control standard cannot be met solely using On-site Stormwater Management BMP's.

Submit an [On-site Stormwater Management Calculator](#) and show the On-site Stormwater Management BMP's and surface designation on the [Standard Drainage and Wastewater Control Plan](#).

Flow Control Required: **Peak Flow Control Standard**

This project site discharges to a **Small Lake Basin** - Bitter Lake, Green Lake, or Haller Lake (SMC 805.050.C.4). Based upon the information provided on the Preliminary Application Form pertaining to land disturbing activity, and existing and proposed hard surfacing this project shall: provide flow control meeting the **Peak Flow Control Standard** per SMC 22.805.080.B.4. The post-development peak flow with a 4% annual probability (25-year recurrence flow) shall not exceed 0.4 cubic feet per second per acre. Additionally, the peak flow with a 50% annual probability (2-year recurrence flow) shall not exceed 0.15 cubic feet per second per acre.

Projects with less than 10,000 sf new plus replaced hard surface can use the [Pre-Sized Flow Control Calculator](#) in lieu of continuous modeling.

Water Quality

No requirements

Wastewater

The wastewater point of discharge (SMC 21.16.070.B) is located at Midvale Ave N.

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a [King County Capacity Charge](#).

Permanent and Temporary Dewatering

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following:
Onsite (infiltration).

Side Sewer

The existing side sewer for a new or converted building or dwelling unit may be reused pursuant to SMC 21.16.240.

In order to reuse an existing side sewer, the [Side Sewer Evaluation and Certification Form](#) must be completed by a licensed engineer.

DPD Land Use Code Requirements

Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

MIDVALE AVE N

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.

<http://www.seattle.gov/transportation/treeplanting.htm>.

Any planting proposed within the ROW must be reviewed and approved by DPD and SDOT.

Land Use

It appears your project will require Streamlined Design Review. A pre-submittal conference will be required. Please see Land Use Code Section 23.41.018.

Pre-Application Site Visit (PASV) Requirements

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

Note: Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

ECA Mapping Unit and Type

Non-ECA

Earth Disturbance

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

Existing ROW Conditions

MIDVALE AVE N

Street conditions:

Concrete paving

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 4 inch inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

It appears that drainage from that discharge point will remain in the gutter line all the way to the nearest inlet structure, but this assessment is preliminary and it is the responsibility of the applicant to meet all relevant SW code requirements.

Potential Impacts to Seattle Parks Property

No parks property in vicinity

Tree Protection

Trees greater than 6 inches in diameter as measured 4.5 ft above ground are present on the site but not shown on the site plan. Show the dripline of

- 1) **all** trees on the site,
- 2) adjacent trees that encroach on the site that are greater than 6 inches in diameter as measured 4.5 ft above ground, and
- 3) **all** trees located in the adjacent ROW.

Include common and scientific names for all trees shown. For more information, see [Director's Rule 16-2008](#) and [Tip 242](#).

Construction Stormwater Control

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual ([DR 21-2015, Volume 2](#)).

Show the following on the [Construction Stormwater Control and Soil Amendment Standard Plan](#):

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or [online](http://web1.seattle.gov/DPD/InspectionRequest/default.aspx) at <http://web1.seattle.gov/DPD/InspectionRequest/default.aspx>.

Inspectors Notes

No unusual site conditions

Seattle City Light Requirements

Easements

SCL power easement is required. Property survey may be required at project's expense.

SCL blanket power easement over the entire parent parcel may be required. Property survey may be required at project's expense. If this is a unit lot subdivision, a blanket easement is needed.

Other requirements: The parent parcel is considered one site. The electrical service to the new buildings will need to be consolidated from one service strike from SCL's distribution system. Per SCL Requirements for Electric Service Connection, <http://www.seattle.gov/light/contractors/resc/>, Chapter 5, page 28: "Single Service Rule", Seattle City Light will provide only one service to a site or building. Additional services will be supplied only at SCL's option and will be agreed to in writing. If subdivided to create separate parcels, each parcel must have a separate service. An easement sufficient in width for an overhead or underground service is required. Clearance from permanent structures and other utilities is also required. Please contact your Electrical Service Representative well in advance of construction for clarification and electrical service advice.

Notes to Applicant

For new service, please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. An Application for Electrical Service must be submitted to Seattle City Light. The Electrical Service Representative should also be contacted to coordinate electrical disconnections prior to demolition and temporary power for construction. Your Electrical Service Representative is: Brandon Crandall, 206-386-9109, brandon.crandall@seattle.gov. Be advised that it is the applicant's responsibility to seek guidance from City Light. Failure to contact City Light early in the permit process could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SDOT Requirements

Based on the information provided at this time, it appears that no street improvements are **required**. All work in the right-of-way requires a permit. Therefore, if you are planning discretionary improvements you should contact SDOT as soon as possible. Be advised that it is the applicant's responsibility to seek guidance from SDOT Street Use should the scope of the project change, or should the applicant become aware of proposed construction in the ROW. Failure to contact SDOT at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SPU Requirements

Water Availability

Your water availability assessment has been approved.

Water Availability Certificate reference number: 20151757

Water Availability Certificate status: Approved with No Changes

Prepared by: Michael Barrett

Existing Water System Information

Proximity of nearest fire hydrant is: 58 feet S of property. Meets standards.

Water Main:

Size: 8 inches

Material: Cast Iron

Class: 150

- Standard

- Abutting

Water Main is available to serve in: Midvale Avenue N

Distance of main to E margin of street is 19 feet.

Public ROW width is 60 feet.

Water Service(s):

Size: 3/4"

Material: Copper

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:

http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos_004542.pdf. For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, Liz.Kain@seattle.gov.

Other Requirements

Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, Michale.Crooks@seattle.gov, or visit the [Licensing and Tax Administration Division website](#).